



We help ideas meet the real world

Attestation of Conformity

No. 2016-567A

Cables for use in construction works Reaction to fire class B2_{ca}

Company

Caleb Cable Industrial Ltd.
#107 Luyuan Rd, Ke Yuan Cheng
Tangxia, Dongguan
Guangdong
China

Product description

Screened communication cable (U/FTP) with solid conductors
4 twisted pairs, LSZH jacket

Product identification

Cat 6A U/FTP 500 MHz FRNC
Part no. CCUFTPCAT6A4PB2

Reaction to fire standards

- EN 50575:2014 including amendment A1:2016
- EN 60332-1-2:2004 including amendment A1:2015
- EN 50399:2011 including amendment A1:2016
- EN 13501-6:2014

Reaction to fire classification

Class B2_{ca}-s1,d1

Technical report

DELTA-T213030-05, DANAK-19/16775

EC Cabling product ID

5240

This product has undergone a one-time test performed by DELTA EC Cabling Group and complies with the requirements for the stated reaction to fire class. The classification has been carried out in accordance with EN 13501-6 for use in relation to the Construction Products Regulation (CPR). This AoC has been revised.

Hørsholm, 20 October 2016

Lars Lindskov Pedersen
Test Manager

Claude Videt
Project Manager

DELTA

Venlighedsvej 4
2970 Hørsholm
Denmark

Tel. +45 72 19 40 00
Fax +45 72 19 40 01
www.madebydelta.com/cable